

CERTIFICATE OF ANALYSES

GENERAL WATER QUALITY PARAMETERS

Date received: 2018-07-04

Date completed: 2018-07-27

Project number: 1000

Report number: 75632

Order number:

Client name: Optimum Holdings

Contact person: Mr. L. Thenerry

Address: 6 Velling Place, Wapadrand,

e-mail: leon@optimumholdings.co.za

Telephone: 082 445 3902

Facsimile:

Mobile: 079 854 7032

Analyses in mg/l (Unless specified otherwise)	Method Identification	Risk	SANS 241 : 2015 Limits	Sample Identification		
				A Raw 16:00 30/06/2018	B Treated 11:25 02/07/2018	
Sample Number				034220	034221	
Date/Time Sampled				N/A	N/A	
pH - Value @ 25 °C	N	WLAB065	Operational	≥5 to ≤ 9.7	7.4	7.4
Electrical Conductivity in mS/m @ 25°C	A	WLAB002	Aesthetic	≤170	68.5	73.3
Total Dissolved Solids @ 180°C	N	WLAB003	Aesthetic	≤1200	372	380
Colour in PtCo Units	N	WLAB006	Aesthetic	≤15	69↓	21↓
Turbidity in N.T.U	A	WLAB005	Operational/Aesthetic	≤1 / ≤5	12↓	0.6
Free Residual Chlorine as Cl ₂	N	WLAB036	Chronic health	≤5	<0.1	1.2
Monochloramine	N	WLAB036	Chronic health	≤3	<0.1	<0.1
Total Alkalinity as CaCO ₃	A	WLAB007	---	---	208	176
Langeller Index at 25°C	N	WLAB053	---	---	-0.3	-0.4
Chloride as Cl	A	WLAB046	Aesthetic	≤300	52	93
Sulphate as SO ₄	A	WLAB046	Acute health/Aesthetic	≤500 / ≤250	56	55
Fluoride as F	A	WLAB014	Chronic health	≤1.5	0.2	<0.2
Nitrate as N	A	WLAB046	Acute health	≤11	0.2	0.6
Nitrite as N	A	WLAB046	Acute health	≤0.9	0.1	0.09
Combined Nitrate & Nitrite	N	WLAB046	Acute health	≤1	0.2	0.1
Free Cyanide as CN (µg/l)	N	WLAB056	Acute health	≤200	<10	<10
Total Organic Carbon as C	N	WLAB060	Chronic health	≤10	13↓	16↓
Phenols (µg/l)	N	WLAB041	Aesthetic	≤10	<10	<10
Microcystin as LR (µg/l)	S	---	Chronic health	≤1	0.23	0.15
Chloroform as CHCl ₃ (µg/l)	N	WLAB059	Chronic health	≤300	<10	14
Bromoform as CHBr ₃ (µg/l)	N	WLAB059	Chronic health	≤100	<10	<10
Dibromochloromethane as CHBr ₂ Cl (µg/l)	N	WLAB059	Chronic health	≤100	<10	<10
Bromodichloromethane as CHBrCl ₂ (µg/l)	N	WLAB059	Chronic health	≤60	<10	<10
Combined Trihalomethanes	N	WLAB059	Chronic health	≤1	<0.10	<0.10
Total Coliform Bacteria / (100 ml)	A	WLAB021	Operational	≤10	>100000↓	0
E. coli / (100 ml)	A	WLAB021	Acute health	Not detected	7800↓	0
Heterotrophic Plate Count / (cfu / 1 ml)	N	WLAB021	Operational	≤1 000	>100000↓	<10
Cryptosporidium species / (10 l)	S	---	Acute health	Not detected	0	0
Giardia species / (10 l)	S	---	Acute health	Not detected	0	0
Somatic Coliphages / (10 ml)	S	---	Operational	Not detected	0	0
Free and Saline Ammonia as N	A	WLAB046	Aesthetic	≤1.5	15↓	15↓



A. van de Wetering - Chemical Technical Signatory



N. Ntuli - Microbiological Technical Signatory

A = Accredited N = Not Accredited S = Subcontracted

Tests marked "Not SANAS Accredited" in this report are not included in the SANAS Schedule of Accreditation for this Laboratory.

Results marked "Subcontracted Test" in this report are not included in the SANAS Schedule of accreditation for this Laboratory.

Sample condition acceptable unless specified on the report.

The information contained in this report is relevant only to the sample/samples supplied to **WATERLAB (Pty) Ltd**. Details of sampling conducted by Waterlab (PTY) Ltd, according to WLAB/Sampling Plan and Procedures/SOP, are available on request.

Bacteriological parameters analysed on: 2018-07-04

CERTIFICATE OF ANALYSES

GENERAL WATER QUALITY PARAMETERS

Date received: 2018-07-04

Date completed: 2018-07-27

Project number: 1000

Report number: 75632

Order number:

Client name: Optimum Holdings

Contact person: Mr. L. Thenerry

Address: 6 Velling Place, Wapadrand,

e-mail: leon@optimumholdings.co.za

Telephone: 082 445 3902

Facsimile:

Mobile: 079 854 7032

Analyses in mg/ℓ (Unless specified otherwise)	Method Identification	Risk	SANS 241 : 2015 Limits	Sample Identification		
				A Raw 16:00 30/06/2018	B Treated 11:25 02/07/2018	
Sample Number				034220	034221	
Date/Time Sampled				N/A	N/A	
Sodium as Na	A	WLAB015	Aesthetic	≤200	64	69
Potassium as K	A	WLAB015	---	---	12.5	12.7
Calcium as Ca	A	WLAB015	---	---	31	30
Magnesium as Mg	A	WLAB015	---	---	15	14
Aluminium as Al (µg/l)	A	WLAB015	Operational	≤300	120	393↓
Antimony as Sb (µg/l)	N	WLAB050	Chronic health	≤20	<1	<1
Arsenic as As (µg/l)	N	WLAB050	Chronic health	≤10	1	1
Barium as Ba (µg/l)	N	WLAB015	Chronic health	≤700	30	<25
Boron as B (µg/l)	N	WLAB015	Chronic health	≤2400	38	38
Cadmium as Cd (µg/l)	A	WLAB015	Chronic health	≤3	<3	<3
Total Chromium as Cr (µg/l)	A	WLAB015	Chronic health	≤50	<25	<25
Copper as Cu (µg/l)	A	WLAB015	Chronic health	≤2000	<10	<10
Iron as Fe (µg/l)	A	WLAB015	Chronic health/Aesthetic	≤ 2000 / ≤300	464↓	<25
Lead as Pb (µg/l)	A	WLAB015	Chronic health	≤10	<10	<10
Manganese as Mn (µg/l)	A	WLAB015	Chronic health/Aesthetic	≤ 400 / ≤100	359↓	330↓
Mercury as Hg (µg/l)	N	WLAB047	Chronic health	≤6	1	1
Nickel as Ni (µg/l)	A	WLAB015	Chronic health	≤70	<25	<25
Selenium as Se (µg/l)	N	WLAB050	Chronic health	≤40	1	1
Uranium as U (µg/l)	N	WLAB050	Chronic health	≤ 30	<1	<1
Zinc as Zn	A	WLAB015	Aesthetic	≤5	<0.025	<0.025
% Balancing	N	---	---	---	99.0	98.1



A. van de Wetering - Chemical Technical Signatory



N. Ntuli - Microbiological Technical Signatory

A = Accredited N = Not Accredited S = Subcontracted

Tests marked "Not SANAS Accredited" in this report are not included in the SANAS Schedule of Accreditation for this Laboratory.

Results marked "Subcontracted Test" in this report are not included in the SANAS Schedule of accreditation for this Laboratory.

Sample condition acceptable unless specified on the report.

The information contained in this report is relevant only to the sample/samples supplied to **WATERLAB (Pty) Ltd**. Details of sampling conducted by Waterlab (PTY) Ltd, according to WLAB/Sampling Plan and Procedures/SOP, are available on request.

Bacteriological parameters analysed on: 2018-07-04

CERTIFICATE OF ANALYSES

GENERAL WATER QUALITY PARAMETERS

Date received: 2018-07-04

Date completed: 2018-07-27

Project number: 1000

Report number: 75632

Order number:

Client name: Optimum Holdings

Contact person: Mr. L. Thenerry

Address: 6 Velling Place, Wapadrand,

e-mail: leon@optimumholdings.co.za

Telephone: 082 445 3902

Facsimile:

Mobile: 079 854 7032

Information regarding accredited analyses

Analysis	Method Identification	Reporting limit	Average Uncertainty
pH Value	WLAB001	0.6	21%
Electrical Conductivity	WLAB002	0.1 mS/m	7%
Total Alkalinity	WLAB007	5 mg/L	10%
Chemical Oxygen Demand	WLAB018	10 mg/L	16%
Sulphate	WLAB046	2 mg/L	14%
Free & Saline Ammonia	WLAB046	0.1 mg/L	14%
Nitrate	WLAB046	0.1 mg/L	6.2%
Nitrite	WLAB046	0.05 mg/L	10%
Ortho Phosphate	WLAB046	0.1 mg/L	26%
Chloride	WLAB046	2 mg/L	10%
Fluoride	WLAB014	0.2 mg/L	7%
Turbidity	WLAB005	0.1 NTU	8%
Sodium	WLAB015	2 mg/L	13%
Potassium	WLAB015	1.0 mg/L	7.3%
Calcium	WLAB015	2 mg/L	7.8%
Magnesium	WLAB015	2 mg/L	8.0%
Aluminium	WLAB015	0.100 mg/L	7.2%
Cadmium	WLAB015	0.005 mg/L	9.1%
Cobalt	WLAB015	0.025 mg/L	4.6%
Chromium	WLAB015	0.025 mg/L	6.8%
Copper	WLAB015	0.025 mg/L	36%
Iron	WLAB015	0.025 mg/L	3.8%
Manganese	WLAB015	0.025 mg/L	4.4%
Nickel	WLAB015	0.025 mg/L	14%
Lead	WLAB015	0.010 mg/L	7.7%
Zinc	WLAB015	0.025 mg/L	23%
Total Coliform Bacteria	WLAB021	0 CFU/100 mL	6.1%
E. coli	WLAB021	0 CFU/100 mL	23%



A. van de Wetering - Chemical Technical Signatory



N. Ntuli - Microbiological Technical Signatory

A = Accredited N = Not Accredited S = Subcontracted

Tests marked "Not SANAS Accredited" in this report are not included in the SANAS Schedule of Accreditation for this Laboratory.

Results marked "Subcontracted Test" in this report are not included in the SANAS Schedule of accreditation for this Laboratory.

Sample condition acceptable unless specified on the report.

The information contained in this report is relevant only to the sample/samples supplied to **WATERLAB (Pty) Ltd**. Details of sampling conducted by Waterlab (PTY) Ltd, according to WLAB/Sampling Plan and Procedures/SOP, are available on request.

Bacteriological parameters analysed on: 2018-07-04